



See detail L-6317A for vault details not shown.
 Refer to L-6317D for additional information.

The Vault Floor shall be a min. of 18" above the flow line of the Storm Sewer or Drainage Ditch. Use of a Sump Pump in lieu of providing adequate drainage is not permitted.

L-6317B.Dwg Revision Date: 11/06/2023

CITY OF COLUMBUS
 DEPARTMENT OF PUBLIC UTILITIES
 DIVISION OF WATER

APPROVED: *[Signature]* 11-17-23
 ADMINISTRATOR DATE

STANDARD DETAIL
 METER VAULT SETTING
 SECTION VIEW
 3" thru 12" METERS

