

City of Columbus UCMR Monitoring Results through May 2024

PFAS compounds included in recently established U.S. EPA National Primary Drinking Water Rules.

			Dublin Road Water Plant		Hap Cremean Water Plant		Parsons Avenue Water Plant	
Substance	Final MCLG (ppt)	Final MCL (ppt)	Range of Detections	Level Found	Range of Detections	Level Found	Range of Detections	Level Found
PFOA	0	4	ND	ND	ND	ND	ND	ND
PFOS	0	4	ND	ND	ND	ND	ND	ND
PFHxS	10	10	ND	ND	ND	ND	ND	ND
PFNA	10	10	ND	ND	ND	ND	ND	ND
GenX (HPFO-DA)	10	10	ND	ND	ND	ND	ND	ND
Two or more of the following in combination: PFBS PFHxS PFNA GenX	Health Index = 1		ND	ND	ND	ND	ND	ND

PFAS compounds not included in recently established U.S. EPA National Primary Drinking Water Rules. The following PFAS compounds are unregulated.

PFBA	NA	NA	5.2-7.3 ppt	6.25 ppt	ND	ND	6 ppt	6 ppt
PFPeA	NA	NA	ND-3.1 ppt	1.6 ppt	ND	ND	3.3 ppt	3.3 ppt
PFHxA	NA	NA	4.1-4.5 ppt	4.3 ppt	ND	ND	ND	ND

ND = Non-detect below the UCMR minimum reporting level

*Additional monitoring will take place in August, and November of 2024.